



EXPANDED METAL ENCLOSURE
(SECURITY)



CUSTOM ENCLOSURE
(SECURITY)



FIBERGLASS ENCLOSURE
(SECURITY/FREEZE)



ARTIFICIAL FIBERGLASS ROCK
(SECURITY/FREEZE)



ALUMINUM ENCLOSURE
(SECURITY/FREEZE)



INSULATED BLANKET ENCLOSURE
(SECURITY/FREEZE)

SECURITY/FREEZE PROTECTION ENCLOSURE

NOTES:

1. FREEZE PROTECTON SHOULD BE CONSIDERED WHEREVER COLD WEATHER DAMAGE IS POSSIBLE. METHODS OF FREEZE PROTECTION ***SHALL NOT*** COVER OR PLUG THE RELIEF VALVE OF A REDUCED PRESSURE PRINCIPLE ASSEMBLY AND SHALL LEAVE THE ASSEMBLY ACCESSIBLE.
2. ALL MANUFACTURED ENCLOSURES SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
3. CUSTOM ENCLOSURES SHALL BE DESIGNED WITH 12" MINIMUM SIDE CLEARANCE AND 24" MINIMUM SIDE CLEARANCE FOR THE RELIEF VALVE OR TEST COCKS.
4. SMALLER CUSTOM ENCLOSURES SHALL BE REMOVABLE TO ALLOW FOR COMPLETE ACCESS AND NOT WEIGH MORE THAN 50 LBS.



UNAPPROVED METHOD OF PROTECTION