



- * SUPPLIED BY EQUIPMENT MANUFACTURER
- NOTES:
1. ST—SHUNT TRIP
 2. FOR VALVES PROVIDE BUTTERFLY VALVE OR BALL VALVE, WHICHEVER HAS LOWER COST.
 3. FILTERS BW ON TIME OR DIFFERENTIAL PRESSURE.
 4. PROVIDE ADJUSTABLE FTW PERIOD. (5 MINUTES)
 5. ≥ 36" OF MEDIA IN EACH VESSEL.

USE OF DOCUMENTS

THIS DOCUMENT, INCLUDING THE INCORPORATED DESIGNS, IS AN INSTRUMENT OF SERVICE FOR THIS PROJECT AND SHALL NOT BE USED FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF KENNEDY/JENKS CONSULTANTS.

| | | | |
|-------------------------|----------|------|----|
| Todd K. Reynolds C59630 | | | |
| DESIGNED | VF | | |
| DRAWN | WL | | |
| CHECKED | TP/JL | | |
| NO. | REVISION | DATE | BY |

Kennedy/Jenks Consultants
Engineers & Scientists

in association with
CH2MHILL

MARIN MUNICIPAL WATER DISTRICT

SEAWATER DESALINATION PILOT PLANT PROGRAM

Kennedy/Jenks Consultants
622 FOLSOM STREET, SAN FRANCISCO, CA 94107

PROCESS AND INSTRUMENTATION DIAGRAM
CONVENTIONAL FILTRATION

| | |
|------------|---------------|
| FILE NAME | |
| JOB NO. | 0468029.00 |
| DATE | 22 MARCH 2005 |
| SHEET | OF |
| P-4 | |

N:\2004\0468029.00 MMWD Seawater Desalination\p4.dwg
PRINT DATE: Mar 30, 2005 1:46pm