



- NOTES:
1. SWRO SHALL SHUTDOWN ON HIGH ORP (ADJUSTABLE) TO PROTECT MEMBRANE ELEMENTS.
  2. CIP PUMP WILL BE USED TO PERFORM MANUAL SYSTEM FLUSH AFTER SHUTDOWN.
  3. PROVIDE MANUAL READING FLOW METERS.

**SUBMITTAL FOR APPROVAL**

N:\2004\0468029.00 MMWD Seawater Desalination\p8.dwg  
PRINT DATE: Feb. 03, 2005 - 4:59pm

**USE OF DOCUMENTS**  
THIS DOCUMENT, INCLUDING THE INCORPORATED DESIGNS, IS AN INSTRUMENT OF SERVICE FOR THIS PROJECT AND SHALL NOT BE USED FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF KENNEDY/JENKS CONSULTANTS.

Todd K. Reynolds C59630			
DESIGNED	VF		
DRAWN	WL		
CHECKED	TKR/JL		
NO.	REVISION	DATE	BY

**Kennedy/Jenks Consultants**  
Engineers & Scientists  
in association with  
**CH2MHILL**

**MARIN MUNICIPAL WATER DISTRICT**  
**SEAWATER DESALINATION PILOT PLANT PROGRAM**  
Kennedy/Jenks Consultants  
622 FOLSOM STREET, SAN FRANCISCO, CA 94107

**PROCESS AND INSTRUMENTATION DIAGRAM**  
**SWRO PILOT UNIT**

FILE NAME	
JOB NO.	0468029.00
DATE	1 Feb. 2005
SHEET	OF
<b>P-8</b>	